

# US Department of Energy Laboratory

## Water Treatment Plant Waste Solidification

**Problem: How to solidify LLRW water for transport across country to the Hanford Nuclear Reservation (WA) without doubling/tripling waste volume?**



**Application of liner to B-25 Box.**

**The water treatment plant at this site generates about 15,000 gallons of liquid waste which must be solidified and shipped to the Hanford site for disposal.**

**The LLRW is solidified in steel B-25 boxes.**



# US Department of Energy Laboratory

## Water Treatment Plant Waste Solidification



The waste is pure liquid and contains contaminants of radioisotopes.

About 50 lbs of *Waste Lock*® is first added to the bottom of the box.

Then, the liquid waste is added on top to a depth of 2-3”.



# US Department of Energy Laboratory

## Water Treatment Plant Waste Solidification



**Additional *Waste Lock*<sup>®</sup> is added to the first gel layer.**

**Again, more liquid waste is added on top of the fresh polymer to a depth of 2-3”.**



**No agitation is applied.**

**The polymer swells as liquid is added. More polymer is added to the top of the gel and then more liquid added to the fresh polymer.**



# US Department of Energy Laboratory

## Water Treatment Plant Waste Solidification



In this step-by-step/layered approach, the entire liquid content of the B-25 box is solidified to meet EPA Paint Filter Test Requirement.

**End result for the B-25 box:**

**350 lbs of Waste Lock®**

**Plus**

**550 gallons (or 4,700 lbs)**

**Time for one box = 2 hours.**

**Weight / Volume Increase:**

***No volume increase.***

***Polymer adds about 7% to weight.***

